



Addendum 1
ARLINGTON ROOF REPLACEMENT
RFP NO. 2021.11.17
December 17, 2021

1. QUESTIONS AND ANSWERS

Q: When we install the downspouts, do we need to do any landscaping?

A: [Sno-Isle Libraries is responsible for any landscaping disturbed.](#)

Q: What is the color selection for the metal standing seam roof option? Can we get the color before the pre-construction meeting date?

A: [We have not selected a color for the metal roof option. However, we have three roof color options we are reviewing in the 24 gauge. The three colors are listed below. We will select a color by the pre-construction meeting date \(January 12, 2022\). Please get pricing and lead times for the three colors below. Depending on the supplier the companies use, they will have other options near these colors so exact color match is not a requirement.](#)



Charcoal Gray SRI-31



Moss Green SRI-26

[Below is a sample of a dark blue color but we would like this in the 24 gauge.](#)



Pacific Blue

END OF ADDENDUM