

SNO-ISLE LIBRARIES

Addendum 1

PARKING LOT/SIDEWALK REPAIRS, MAINTENANCE, AND STRIPING

SERVICES | BID NO. 2023.04.12

April 28, 2023

QUESTIONS AND ANSWERS

Q: Which way will the arrows go?

A: The striping at Granite Falls will not include directional arrows as it is a single entrance parking lot and has a pretty straightforward traffic flow.

Q: Does a Bid bond have to be submitted with the bid?

A: While a Payment/Performance bond and Retainage bond will be required for this project once awarded, Sno-Isle Libraries is not requiring a Bid bond.

Q: Is pressure washing required for all curbing or just the curbing to be painted?

A: Any curbing that is to be painted will need to be pressure washed in preparation for painting, which includes all curbing that is presently or has previously been painted.

Q: How many coats of asphalt sealer does the job require?

A: Two coats of asphalt sealer will be required for this job.

Q: Will Sno-Isle Libraries need a 3rd party inspection firm for this project?

A: No, Sno-Isle Libraries will not be requiring a 3rd party inspection firm for this project.

Q: Can we bid on just the Clinton and Freeland Libraries, or do bidders have to bid on all four locations?

A: We are going to allow bidders to bid on either the entire project of all 4 library sites, or bidders can bid by county. We will not allow bids on single sites.

END OF ADDENDUM