

SNO-ISLE LIBRARIES

Addendum 7

LANGLEY LIBRARY TENANT IMPROVEMENTS | NO.

2023.07.19LNG

September 5, 2023

Changes to Bid Documents

[ADDENDUM 7 - Attachment A Changes to Drawings.pdf](#) - Changes to Drawings A101, A501, E002

Substitution Requests and Bid Clarifications

- Q. Substitution Package for Lighting and Controls submitted by SeaTac Lighting & Controls.
- A. [ADDENDUM 7 - Attachment B Substitution Request.pdf](#) - Substitution Request Form
- Q. There appears to be some sections missing in the bid documents for controls and flex duct. Section 23 33 46 Flexible Ducts and section 23 09 23 Direct Digital Control (DDC) system for HVAC are mentioned in the specs, but the actual spec sections covering them seems to be missing. Can we get those spec sections?
- A. Direct Digital Control (DDC) system is not a part of the scope. Mention of it will be removed from the contract documents. Flexible Ducts can be quoted as typical. Further details will need to be resolved in the Request For Information (RFI) process.

END OF ADDENDUM